



30USW Block	#10 sds USKW to block	Allowable Tie-In Truss Reaction / Uplift (lbs)			
		Girder Truss Bottom Chord			
		035	046	057	073
035	2	485 (2)	485 (2)	485 (2)	485 (2)
	3	725 (3)	725 (3)	725 (3)	725 (3)
	4	970 (4)	970 (4)	970 (4)	970 (4)
046	2	840 (4)	840 (2)	840 (2)	840 (2)
	3	1255 (6)	1255 (3)	1255 (3)	1255 (3)
	4	1675 (8)	1675 (4)	1675 (4)	1675 (4)
057	2	1025 (6)	1025 (3)	1025 (2)	1025 (2)
	3	1535 (8)	1535 (4)	1535 (3)	1535 (3)
	4	1900 (8)	1900 (5)	1900 (4)	1900 (4)

( ) indicates number of #10 sds attaching block to girder bottom chord

Notes:

1. USKW flange orientation at girder may be as shown or reversed to allow for screw installation.



METAL FRAMING a division of MITEK®  
 www.AEGISMETALFRAMING.COM  
 14515 N. Outer 40 Drive Suite 110  
 Chesterfield, MO 63017  
 Phone:866/902-3447 Fax:314/434-5234

TRUSS TO TRUSS CONNECTION  
 35 USKW to 30USW Block

DETAIL NO.

US2US-13.1

CATEGORY

STANDARD DETAILS

DATE

8/21/2008