



Maximum Load Pa (lbs) Supported by Bottom Chords			
Bottom Chord Thickness (mil)	Screws block to chord		
	2	3	4
035	970	1455	1940
046	1675	2510	3350
057 min	1865	2800	3735

UniStrut® is a registered trademark or trademark of UniStrut Corporation

1. Load assumed placed at midspan of UniStrut
2. Design of UniStrut members and connection of load by others.
3. This details does not imply adequacy of trusses involved. Truss designs must include load.



www.AegisMetalFraming.com

14515 N. Outer 40 Drive - Suite 110  
Chesterfield, MO 63017

Phone: (866) 902-3447 Fax: (314) 434-5234

## ULTRA-SPAN TRUSS BOTTOM CHORD LOAD SUPPORT WITH UNISTRUT®

DETAIL NO.

# LD2US-3

CATEGORY

STANDARD DETAILS

DATE

9/2010